

DISTRICT/CTDEEP LIMITS

Updated 2020

	CTDEEP Sewer Limits mg/l	District Liquid Waste Limits (2018) mg/l	District Sludge Limits (2018) mg/kg	Over the Road Program Approved Limits (2018) mg/kg
Aluminum		20	8,000	8,000
Arsenic	0.05	0.5	5	5
Barium	5.0	5.0	800	800
Beryllium		1.0	20	20
Boron	5.0	5.0	100	100
Cadmium	0.1	1.0	20	20
Chloride		100	3,000	3,000
Chromium, Total	1.0	2.0	800	800
Chromium, Hexavalent	0.1	1.0	200	200
Copper	1.0	5.0	3,000	3,000
Cyanide, Total	0.65	1.0	50	50
Iron, Total		20	25,000	25,000
Lead	0.1	1.0	1,000	1,000
Magnesium	100	100	5,000	5,000
Manganese	5.0	20	2,000	2,000
Mercury	0.01	0.02	8	8
Nickel	1.0	5.0	1,000	1,000
Polychlorinated Biphenyl		2.0	20	20
Potassium		500	2,000	2,000
Silver	0.1	500	2,000	2,000
Sodium		500	5,000	5,000
Tin	2.0			
Zinc	1.0	5.0	5,000	5,000
Combined Potassium and Sodium			6,000	6,000

The pH shall not be less than 5.0 nor greater than 9.0, and shall not have any other corrosive property.